



DOUBLE CHECK SIZE	UTILITY VAULT CO. - MODEL NO.	
	VAULT	VAULT DOOR
3" & 4"	577-LA	332P
6"	676-WA	332P
8"	687-WA	332P

NOTES:

1. Finished grade shall slope away from the vault cover so as to prevent ponding around the cover.
2. This is to be a private facility, governed by *UPC* and *Oregon Dept. of Human Services*, as applicable.
3. Vault door mechanisms shall not project below the ceiling of the vault interior.



City Of Beaverton

**ENGINEERING
DEPARTMENT**

UTILITIES ENGINEER
David A. Winship, P.E.

DATE
6 - 10 - 04

DRAWN BY
CDH - WD

DRAWING NO.
670

**PRIVATE
DOUBLE CHECK
BACKFLOW PREVENTER VAULT**